

COPY

ADOPTIVE HOME FIRE INSPECTION

COPY

Name of Facility: \_\_\_\_\_ Type: \_\_ Foster Home \_\_ Group Home

Address: \_\_\_\_\_

Inspection Date: \_\_\_\_\_ Time: \_\_\_\_\_ Purpose: \_\_ Annual \_\_ Regular \_\_ Follow-up

Yes No N/A

Yes	No	N/A	
			1. There are at least two unblocked exits from the home (can include windows).
			2. Electrical wiring system appears to meet codes.
			3. Electrical outlets in rooms used by children have child proof covers.
			4. Fuses or circuit breakers appear in good operating condition.
			5. Extension Cords are used properly.
			6. Space Heaters: Enclosed, Vented properly,
			7. Gas appliances have metal tubing and metal connectors.
			8. HVAC system is inspected annually by a qualified inspector.
			9. Wood burning or gas fireplaces are protected with a screen or guard.
			10. Combustibles are stored or placed well away from any heat source.
			11. All lighters or matches are kept out of reach of children.
			12. Flammable liquids are stored safely and properly (children and heat).
			13. Paint is stored in tightly closed metal containers.
			14. The premises are free of rubbish (attic, garage, outside).
			15. There is a Multi-purpose (ABC) minimum 2A10BC fire extinguisher in the kitchen area.
			16. Fire extinguisher is properly maintained and serviced annually.
			17. Family has an evacuation plan for emergencies.
			18. Fire drills are practiced at least quarterly.
			19. There is a method to alert family to a fire.
			20. Smoke detectors are installed and maintained.

Additional Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

COPY

Received by: \_\_\_\_\_

Title: \_\_\_\_\_

Inspected by: \_\_\_\_\_

Title: \_\_\_\_\_